



TECHNICAL FAX

Est_Histry.doc

TECHNICAL FAX # 069801

(3) Command ↘

↙ Command Type

CMD 04:02:30 02-07-98 ENABLE SRVC GRP XXXX:0001
 ↑ Time ↑ Date

Example (3) indicates that at 4:02 AM on February 7, 1998 Service Group 1 was enabled. "XXXX"– Entire network affected.

(4) Command ↘

↙ Command Type

CMD 04:04:30 02-07-98 ACTIVATE CLEAR HISTORY PP:01
 ↑ Time ↑ Date

Example (4) indicates that at 4:04 AM on February 7, 1998 the operator cleared the History for Cabinet 01.

Table 1 Device Type List

Type	Type Code	Type	Type Code
Smoke	0	GroundFault	24
Pull	1	InternalTrouble	25
Heat	2	BadType	26
Waterflow	3	BadPersonality	27
Stageone	4	UnexpectedDevice	28
Zone	5	CommonTrouble	29
AlarmVerify	6	RelayConfirmation	30
PreAlarm	7	Monitor	31
Security	8	LocalMonitor	32
Station	9	Damper	33
Emergency	10	Fan	34
Supervisory	11	Door	35
Valve	12	Switch	36
GateValve	13	FirePhone	37
Tamper	14	VerifiedPreAlarm	38
Temperature	15	DeviceCompatibilityFault	39
Power	16	LogicAND	40
Signal	17	LogicMATRIX	41
TroubleOpen	18	ServiceGroup	42
TroubleShort	19	TimeControl	43
LocalTrouble	20	GuardPatrol	44
MaintAlert	21	CheckInGroup	45
DirtyHead	22	InternalUseOnly	46
DeviceComm	23	Disabled	47

If you have any questions regarding this application please contact EST Technical Services in Sarasota, Florida at 800 655-4497 or (941) 739-4300.